


GROOVE  
 57.5 mm O.D x  
 42.5 mm I.D x  
 6.0/6.1 mm  
 DEEP.




PSZ

FURNACE COMPONENT. DRAWING 3106 REV  
 ITEM 14.

TOLERANCES ±0.3 UNLESS STATED

**PATERSON INSTRUMENTS PTY LTD**  
 ACN 008 644 273

ANU RESEARCH SCHOOL OF EARTH SCIENCES  
 Canberra ACT 0200, Australia




12 HOLES EQUISPACED  
ON PCD 50 WITH  
LIP TO LOCATE  $\phi 3$   
 $Al_2O_3$  LINER

14 STAINLESS  
STEEL (18/8)


FOR USE WITH 1 MM THICK  
PSZ INSULATORS UNDER CONNECTORS

ALTERNATIVELY: PSZ WITH  
5.000E 57.5 OD  $\times$  42.5 ID  $\times$  6 DEEP  
& PLAIN HOLES  $\phi 2$




21 18/8 STAINLESS  
STEEL

ALTERNATIVELY: PSZ



22 STAINLESS STEEL  
SPRING SHEET



23 SS OR  
BRASS



DIMENSIONS IN MILLIMETERS -  
DO NOT SCALE

TOLERANCES  $\pm 0.3$  UNLESS STATED


PATERSON INSTRUMENTS PTY LTD

HPT TESTING MACHINE  
FURNACE COMPONENTS  
DETAILS 14 & 21 TO 23



SCALE DATE



(20) MACOR OR PSZ




(21) PSZ








(23) BRASS  
OR SS

*Handwritten notes:*  
Sample  
Material  
PSZ  
Macor  
Brass

DIMENSIONS IN MILLIMETRES DO NOT SCALE		ANU RESEARCH SCHOOL OF EARTH SCIENCES	
TOLERANCES $\pm$ UNLESS STATED		HIGH PRESSURE/TEMPERATURE TESTING MACHINE FURNACE ASSEMBLY DETAILS (20) TO (23)	
A3	SCALE	DATE	DRAWING NO 3106





CUT FROM APA2  
ALUMINA PAPER  
56-50D 385ID  
(2 LAYERS)

17a PSZ


DIMENSIONS IN MILLIMETERS -  
DO NOT SCALE

TOLERANCES ± 0.3 UNLESS STATED


PATERSON INSTRUMENTS PTY LTD

HPT TESTING MACHINE  
FURNACE ASSEMBLY  
DETAIL (17) - ALTERNATIVE INSULATION

SCALE | DATE | DRAWING NO.











18 ZIRCAR APA2  
 ALUMINA PAPER  
 9 PIECES 62 x 165  
 WITH CUT-OUT 5 x 29  
 AT BOTTOM OF 3 TO  
 ACCOMMODATE TO 21

See also note in 31074  
 assembly drawing




19 ZIRCAR APA2  
 ALUMINA PAPER  
 6 PIECES

17 ZIRCAR ASH  
 (ALUMINA-SILICA)  
 FIBRE INSULATION  
 3" OD 1" ID



WIRING CONNECTIONS - VIEW FROM ABOVE

MIN 2.0 2.5










DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCES  $\pm$  UNLESS STATED

ANU RESEARCH SCHOOL OF EARTH SCIENCES

HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
FURNACE ASSEMBLY  
DETAILS 17 TO 19 ETC


A3 SCALE DATE DRAWING NO 31074




DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCES ± UNLESS STATED

PATERSON INSTRUMENTS PTY LTD  
HPT TESTING MACHINE  
FURNACE ASSEMBLY  
DETAILS OF CONNECTORS







17b



17a

17c

17d




17a) PSZ



17b) MACOR OR PSZ

17d) MACOR OR PSZ



17c) SALI OR POROUS ALUMINA ETC

DIMENSIONS IN MILLIMETERS - DO NOT SCALE

TOLERANCES  $\pm 0.3$  UNLESS STATED

PATERSON INSTRUMENTS PTY LTD

HPT TESTING MACHINE  
 FURNACE ASSEMBLY  
 DETAIL (17) - ALTERNATIVE INSULATION

43	SCALE	DATE	DRAWING NO 3107a
----	-------	------	------------------



**PATERSON INSTRUMENTS PTY LTD**

ACN 008 644 273

ANU RESEARCH SCHOOL OF EARTH SCIENCES  
Canberra ACT 0200, Australia

Prof M S Paterson

Tel: +61 6 249 2497

Fax: +61 6 249 0738

**Facsimile Message**

Date: 7 July 1995

No. of pages: 3

To: Fax No. +33-67-14-36-03

Name Dr David Mainprice

Address Laboratoire de Tectonophysique,  
Universite Montpellier II  
34095 Montpellier cedex 05  
France

Dear David,


I attach the two furnace drawings mentioned in my e-mail message.

The differences to look at are in parts 14 and 17. Part 14 now overlaps the top of the core and is a snug fit on it as well as on the outer can (the earlier version had alumina paper on the OD). Then the insulation 17, which was previously fibre (such as Zircar ASH), is now a combination of PSZ, precision ground to fit together with minimal gaps (parts 17a, b and d), and an inner fibre insulation 17c. Both the outer PSZ piece and the fibre insulation are spring loaded inwards by alumina paper on their OD's, so as to follow the thermal expansion. I think that this device is not working 100% with the fibre insulation as mentioned in my email but I am optimistic that this can be fixed. Here I have so far used a hard insulation called SALI for its greater refractoriness but may revert to ASH which is itself a bit springy.

The PSZ is more thermally conducting than the ASH so the power consumption is a bit greater but not to an extent that matters (I plan to put a couple extra turns in the bottom winding in future to drop the bottom current back a bit). Such a furnace runs quite readily up to 1300°C and I have had one higher. They should have much better life at high temperature than the earlier furnaces.

Best wishes,

1990  
VERSION



1990  
VERSION

DIMENSIONS IN MILLIMETRES  
DO NOT SCALE


ANU RESEARCH SCHOOL OF EARTH SCIENCES  
HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
FURNACE ASSEMBLY  
GENERAL VIEW

A3

SCALE  
1:1

DATE  
AUG 1990

DRAWING NO 3100




1995  
 VERSION

DIMENSIONS IN MILLIMETRES  
DO NOT SCALE


ANU RESEARCH SCHOOL OF EARTH SCIENCES  
 HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
 FURNACE ASSEMBLY  
 GENERAL VIEW

A3	SCALE 1:1	DATE AUG 1990	DRAWING NO 3100
----	--------------	------------------	--------------------







Ansicht M 1:1



19.6.92  
 alle Bohrungen mit  
 Prüfstein prüfen




M. Naumann				
Datum	3.7.96	1 x	M.2:1	Material 1.2344 / 1.2343
Z.-Nummer	P 4.2.5	Z.-Titel Paterson-Apparatur Furnace - Topplatte		
GFZ Potsdam				



M. Naumann					
Datum	3.7.96	1 x	M 2:1	Material	1.2344 / 1.2343
Z.-Nummer	P 4.2.6	Z.-Titel			
GFZ Potsdam		Paterson-Apparatur Furnace - Bodenplatte			




1




M. Naumann			
Datum	18.10.96	je 3x M 1:1	Material <i>Al203 porös KVS 174/400</i>
Z.-Nunmer	P 4.2.7	Z.-Titel	Paterson-Apparatur Furnace - Aluash
GFZ Potsdam			

1




2





Die Nuten 1mm tief bei jeweils nur einem Teil fertigen.


M. Naumann			
Datum	7.7.97	je 3x M 1:1	Material PSZ
Z.-Nunmer	P 4.2.8	Z.-Titel	Paterson-Apparatur Furnace - PSZ-Segmente
GFZ Potsdam			



Einzelheit X (Nut A + B):  
M 2:1



Einzelheit Y (Nut C):  
M 2:1








Länge der Nuten / Lage der Bohrung

Teil	A	B	C
1	34	56	55.5
2	58.5	111.5	85.5
3	110	135	115.5

M. Naumann				
Datum	7.7.97	3x	M 1:1	Material PSZ
Z.-Nummer	P 4.2.9	Z.-Titel Paterson-Apparatur Furnace - PSZ-Segmente		
GFZ Potsdam				


SPEC. TO UNIFORM TUBES INC.  
 0.591" ± 0.001" ID  
 0.509" ± 0.001" WT



0.70714

DIMENSIONS IN MILLIMETRES  
 DO NOT SCALE

TOLERANCES ± 0.3 UNLESS STATED



ACN 008 644 273

PATERSON INSTRUMENTS PTY LTD

HPT TESTING MACHINE  
 SPECIMEN ASSEMBLY  
 GENERAL ARRGT. & PISTON/JACKET DETAIL

A3


SCALE  
 1:1

DATE  
 SEPT 1994


DRAWING NO 3102

REPLACES 3102 REV & ORIGINAL 3102





SWEEP GAS VOL 4.00 ML  
 RATIO 10:1  
 BORE 41  
 STROKE 302  
 OIL CAPACITY 4 LITRES



DIMENSIONS IN MILLIMETRES  
 DO NOT SCALE


TOLERANCES  $\pm$  UNLESS STATED

EXCLUSIVELY LICENCED TO PATERSON INSTRUMENTS PTY LTD

ANU RESEARCH SCHOOL OF EARTH SCIENCES

HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
 INTENSIFIER  
 GENERAL ASSEMBLY

A3	SCALE 1:2.5	DATE AUG 1989	DRAWING NO 2300 <small>REVISED FEB 1993</small>
----	----------------	------------------	----------------------------------------------------



PRECISE SENSORS 114-3  
60,000 PSI (414 MPa)

NOVA 520-1436  
RUPTURE DISK  
200 MPa DISK  
521-9590-19

GAS BOOSTER  
HASKEL ACT-62/152 H

INTENSIFIER

OIL PUMP  
HASKEL AW 10

SOLENOID VALVE  
NC  
NOVA 530-0234  
-6  
IV OFFSET CROSS

MAIN INTENSIFIER  
RELEASE VALVE  
NOVA 530-0232  
2WAY ANGLE II  
520-2333

METERING  
RELEASE VALVE  
NOVA 530-5232  
II 2-WAY ANGLE

RUPTURE DISK  
30 MPa DISK  
521-9590-7

RELEASE VALVE  
NOVA 530-0433  
III CROSS

DUMP VALVE  
NOVA 530-0234  
IV OFFSET CROSS

TOP SOL-70-00  
CONFINING  
PRESSURE  
GAUGE

NOVA 520-1436  
700 MPa DISK  
521-9590-38

DNSTR.  
PRESSURE  
GAUGE  
PI 5010-18

PRECISE  
SENSORS  
114-3  
60,000 PSI  
(414 MPa)

EXCLUSIVELY LICENCED TO PATERSON INSTRUMENTS PTY LTD

DIMENSIONS IN MILLIMETRES  
DO NOT SCALE


TOLERANCES ± UNLESS STATED

ANU RESEARCH SCHOOL OF EARTH SCIENCES


HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
HIGH PRESSURE PLUMBING  
LAYOUT

A3	SCALE	DATE MAR 1989	DRAWING NO 2109
----	-------	------------------	--------------------


REVISED JAN 1983, JULY 1992, JAN 1995



DIMENSIONS IN MILLIMETERS - DO NOT SCALE		PATERSON INSTRUMENTS PTY LTD	
TOLERANCES ± UNLESS STATED		HPT TESTING MACHINE PORE FLUID VOLUMOMETER GENERAL ARRANGEMENT	
ACN 008 644 273	A3	SCALE 1:1	DATE JUNE 1994
			DRAWING NO 5000 REV







DIMENSIONS IN MILLIMETRES  
DO NOT SCALE



TOLERANCE  $\pm$  UNLESS STATED

ANU-RESEARCH SCHOOL OF EARTH SCIENCES  
HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
PRESSURE VESSEL ASSEMBLY  
- UPPER PARTS, REVISED

EXCLUSIVELY LICENCED TO  
PATERSON INSTRUMENTS PTY LTD


A3	SCALE 1:1	DATE JULY 1993	DRAWING NO 2100 B REV
----	--------------	-------------------	-----------------------





DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCES  $\pm$  UNLESS STATED



ACN 008 644 273

PATERSON INSTRUMENTS PTY LTD


HPT TESTING MACHINE  
PORE FLUID SYSTEM  
GENERAL CONFIGURATION

A3

SCALE  
1:2

DATE  
JULY 1994


DRAWING NO 5009



TRANSDUCER TECHNIQUES  
SWP-20K COMP-TENSION  
LOAD CELL FOR EXTERNAL  
FORCE MEASUREMENT

HPT TESTING MACHINE  
AXIAL ACTUATOR ASSEMBLY

DRAWING NO: 2400  
SCALE: 1:2  
JULY 1994



DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCES  $\pm$  UNLESS STATED

LENGTH OF PRESSURE VESSEL = 640  
BORE " " " = 65

ACN 008 644 273

PATERSON INSTRUMENTS PTY LTD

HPT TESTING MACHINE  
PRESSURE VESSEL ASSEMBLY  
GENERAL ARRANGEMENT - LOWER PARTS


A3

SCALE  
1:1

DATE  
APR 1994

DRAWING NO 2100 C REV





DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCES ± UNLESS STATED

LENGTH OF PRESSURE VESSEL = 640  
BORE " " " = 65

ACN 008 644 273

PATERSON INSTRUMENTS PTY LTD



HPT TESTING MACHINE  
PRESSURE VESSEL ASSEMBLY  
GENERAL ARRANGEMENT - LOWER PARTS

A3

SCALE  
1:1

DATE  
APR 1994

DRAWING NO 2100 C REV



Die scharfen Kanten an der 45°-Phase leicht brechen.



Alle Flächen polieren ( $R_z=0.4$ ).

Wärmebehandlung:

315°C / 3h (Lösungsgeglüht - F420A - >rund130)


M. Naumann				
Datum 17.05.00	je 1x	M 1:1	Material 1: Teflon / 2: CuBe2	
Z.-Nunmer P.10.8.0	Z.-Titel Paterson - App.			
GFZ Potsdam	Intensifier - Mitre / Back-up			

A-A




Detail X  
(um 90° bzw. 30° gedreht)

*rotated*





Zusammenbau (M1:2)



*all dimensions in mm.*



M. Naumann				Material	Alu
Datum	28.4.94	3 x	M 1:1	Z.-Titel	Montage Ofen - Körper
Z.-Nunmer	1				
	GFZ Potsdam				




all dimensions in mm.

	M. Naumann			
Datum	28.4.94	1: 1x 2: 2x	M 1:1	Material Aluminium.
Z.-Nummer	3			Z.-Titel Montage Ofen - furnace disks 1 and 2 Scheibe 1 und 2






Löten/Solder




all dimensions in mm.

	M. Naumann			
Datum	18.5.95	2 x	M 2:1	Material Messing/Brass.
Z.-Nunmer				Z.-Titel Thermocouple-housing Thermoelement-Hül
	GFZ Potsdam			





SWEEP GAS VOL 4.00 ML  
 RATIO 10:1  
 BORE 41  
 STROKE 302  
 OIL CAPACITY 4 LITRES



DIMENSIONS IN MILLIMETRES  
 DO NOT SCALE

TOLERANCES  $\pm$  UNLESS STATED

EXCLUSIVELY LICENCED TO PATERSON INSTRUMENTS PTY LTD

ANU RESEARCH SCHOOL OF EARTH SCIENCES


HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
 INTENSIFIER  
 GENERAL ASSEMBLY

A3

SCALE  
 1:2.5

DATE  
 AUG 1989

DRAWING NO 2300  
 REVISED FEB 1993



PRECISE SENSORS 114-3  
60,000 PSI (414 MPa)

NOVA 520-1436  
RUPTURE DISK  
200 MPa DISK  
521-9590-19

GAS BOOSTER  
HASKEL ACT-62/152 M

INTENSIFIER  
520-2433

OIL PUMP  
HASKEL AW10

PRESSURE VESSEL

EXCLUSIVELY LICENCED TO PATERSON INSTRUMENTS PTY LTD

DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

ANU RESEARCH SCHOOL OF EARTH SCIENCES


TOLERANCES ± UNLESS STATED

HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
HIGH PRESSURE PLUMBING  
LAYOUT

DNSTR. PRESSURE GAUGE  
PI 5010-18  
PRECISE SENSORS  
114-3  
60,000 PSI  
(414 MPa)

A3	SCALE	DATE MAR 1989	DRAWING NO 2109
----	-------	------------------	-----------------

REVISED JAN 1933, JULY 1944, JAN 1955



PRESSURE TRANSDUCER  
PRECISE SENSORS 114-3  
60 000 PSI  
OR 100 000 PSI

O-RINGS 012  
& 010 (or 809)

FOR REVISED LVDT & LIMIT SWITCHES ARRGT  
SEE DRG 5007

SCHAEVITZ LVDT HR1000-006

BALL NUT


32x5 BALL SCREW

HARMONIC DRIVE  
HDC-3C-YY-2A-160


LOVEJOY COUPLING  
L-050.250

PRINTED MOTORS MOTOR  
GM9-100-3T-200Z

TOTAL LENGTH WITH MOTOR & P. TRANSDUCER 601



DIMENSIONS IN MILLIMETERS - DO NOT SCALE		PATERSON INSTRUMENTS PTY LTD	
TOLERANCES ± UNLESS STATED		HPT TESTING MACHINE PORE FLUID VOLUMOMETER GENERAL ARRANGEMENT	
ACN 008 644 273	A3	SCALE 1:1	DATE JUNE 1994
			DRAWING NO 5000 REV



DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCE  $\pm$  UNLESS STATED

EXCLUSIVELY LICENCED TO  
PATERSON INSTRUMENTS PTY LTD

ANU-RESEARCH SCHOOL OF EARTH SCIENCES  
HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
PRESSURE VESSEL ASSEMBLY  
- UPPER PARTS, REVISED




A3

SCALE  
1:1

DATE  
JULY 1993


DRAWING NO 2100 B REV.





DIMENSIONS IN MILLIMETRES  
DO NOT SCALE

TOLERANCES ± UNLESS STATED



ACN 008 644 273

PATERSON INSTRUMENTS PTY LTD


HPT TESTING MACHINE  
PORE FLUID SYSTEM  
GENERAL CONFIGURATION

A3

SCALE  
1:2

DATE  
JULY 1994

DRAWING NO 5009



2204-4

2203-3

2205-5 (6)

INTERNAL FORCE

5010-18  
DOWN-STREAM PORE PRESSURE TRANSDUCER

LOAD CELL

TRANSDUCER TECHNIQUES  
SWP-ZOK COMP-TENSION  
LOAD CELL FOR EXTERNAL  
FORCE MEASUREMENT

2205-6

POSITION

2201-1

(3) BALL SCREW  
10 MM LEAD

SCHAEVITZ 1000 DC-E  
DC-LVDT RANGE ±25 MM

HARMONIC DRIVE  
HDC-111 200:1

CIRCLED NUMBERS REFER  
TO DRAWINGS 2401-2412

HPT TESTING MACHINE  
AXIAL ACTUATOR ASSEMBLY

DRAWING NO: 2400  
SCALE: 1:2  
JULY 1994

PATERSON INSTRUMENTS PTY LTD

PRINTED MOTORS  
GM-12-300-9T  
3000 RPM MAX SPEED  
0.30 NM MAX TORQUE

190

44.5

350

85.5

30

258

400

257

(2)

(9)

(10)

(21)

(1)

(8)

(6)

(11)

(4)

(12)

(13)

(14)

(5)

(15)

(7)

(19)






(16)

(17)

(20)

(18)


SPEC. TO UNIFORM TUBES INC.  
 0.591" ± 0.001" ID  
 0.009" ± 0.001" WT



0.707 14

DIMENSIONS IN MILLIMETRES  
 DO NOT SCALE

TOLERANCES ± 0.3 UNLESS STATED



ACN 008 644 273

PATERSON INSTRUMENTS PTY LTD


HPT TESTING MACHINE  
 SPECIMEN ASSEMBLY  
 GENERAL ARRGT. & PISTON/JACKET DETAIL

A3


SCALE  
 1:1

DATE  
 SEPT 1994

DRAWING NO 3102



MATERIAL: ASSAB 709  
OR SIMILAR



DIMENSIONS IN MILLIMETRES  
DO NOT SCALE  
TOLERANCES UNLESS STATED




EXCLUSIVELY LICENCED TO PATERSON INSTRUMENTS PTY LT.

ANU RESEARCH SCHOOL OF EARTH SCIENCES  
HIGH PRESSURE/TEMPERATURE TESTING MACHINE  
PRESSURE VESSEL ASSEMBLY  
DETAIL (13) - CAP FOR BOTTOM CLOSURE PLUG

A3	SCALE 2:1	DATE AUG 1989	DRAWING NO L102
----	--------------	------------------	--------------------




REV MAR 1994






all dimensions in mm

M. Naumann				
Datum	28.4.94	1,2: 1x 3: 3x	M 1:1	Material <i>aluminium</i> 1,2: Alu / 3: St <i>steel?</i>
Z.-Nummer	2			Z.-Titel Montage Ofen - rod 1 rod 2 handle Stah 1 Stah 2 Kna




	M. Naumann				
Datum	18.5.95	2 x	M 2:1	Material	Messing
Z.-Nunmer				Z.-Titel	The moe lement -Hülse
	GFZ Potsdam				



coat windings and leads of cement

Zircar Alumina type 30 A



Zircar ceramic

two layers of APA-2 (one on each side of lead)

two layers of APA-2

two layers APA-2


Building

(17) use outer steel pieces to form outer APA-2 layer

1251  
1251  
1809



- Ⓐ. 1 outer layer of APA-2 to match Zircor 30 piece. (same length as sleeve)
- Ⓑ. place Zircor 30 piece at the end ceramic pieces on, place APA-2 (1 layer) below ceramic pieces.
- Ⓒ. place 2 layers APA-2 on inner part of A-30 piece.
- Ⓓ. 1 layer on both "sides" of A-30 piece

R169+








Thermocouple.




thermocouple.

B-Series - multicontact.  
(Keyed).



additio 10/APR/95

top view:



OB - Keyed connector




Dear Mervyn,

here is a sketch of the buckled load cell cap and some answers to your questions:

- we exchanged the 334 O-ring before we focussed on the electrical feed-throughs. Maybe it was the 400 MPa confining pressure that did it. I had been up there quite a bit in the recent past. One of the O-rings on one of the feed-throughs was in fact slightly damaged. It was the one which surrounds a small zirconia (?) disk.

- the solid block we used was the furnace substitute with the spherical indent.

- here is a sketch of the load cell cap: you are correct - it is not part #8 of #4220, but rather the piece which is visible on #2100 C REV. 'beyond salvage' means that a narrow (previously straight) ridge just above the thread is buckled. The thread itself is stripped. The stripping presumably occurred when we unscrewed the protective cap. We did this because it appeared to be the smallest bullet to bite. Inside the protective cap is trapped part #8 of drawing #4220. Due to the buckling it can not slip out.




- now on to the scoring of the surface of the plug which houses the electrical leads: because there was material caught up between this surface and the interior surface of the outermost hardened steel casing the load cell plugs did not rotate freely when we unscrewed the load cell cap. The twist was large enough to cause a radial crack in the plastic cover. There were plastic and metal (origin unknown: maybe stripped thread?) next to the solder connections of the electrical leads. So we can not say where the foreign material came from, but I am quite convinced that the score is new and not an inherited one. I don't think you mentioned the 'old' score when we looked at the internal load cell. In any event: we polished the surfaces of the plug and casing with a small hand-held dremel, which seemed to work fine. Now the plugs slides in easily and rotated freely inside the casing. One question though: why does the clearing have to be so narrow? From what I understand, the cylindrical surface is not a bearing/sealing surface. Also bending moments would only occur if the surfaces actually touched. Is the width necessary to provide a good face seal against the lower piston?

Anyway, the internal load cell on the bench - when connected - gives a zero of -3kN ; this is not an unusual offset; so I do not expect any more 'lower-level' fundamental zeroing to be done.

I hope I clarified some points of my previous message and that the drawing makes things a little better to understand.

Thanks very much for your prompt reply.

All the best  
Gunter





(17) ZIRCAR ASH  
(ALUMINA-SILICA)  
FIBRE INSULATION  
3'OD 1'ID



(18) ZIRCAR APA2  
ALUMINA PAPER  
9 PIECES 62 x 165  
WITH CUT-OUT 5 x 25  
AT BOTTOM OF 3 TO  
ACCOMMODATE TO (21)

See also note on 3107a  
assembly drawing

(19) ZIRCAR APA 2  
ALUMINA PAPER  
6 PIECES



WIRING CONNECTIONS - VIEW FROM ABOVE




DIMENSIONS IN MILLIMETRES DO NOT SCALE		ANU RESEARCH SCHOOL OF EARTH SCIENCES	
TOLERANCES ± UNLESS STATED		HIGH PRESSURE/TEMPERATURE TESTING MACHINE FURNACE ASSEMBLY DETAILS (17) TO (19) ETC	
A3	SCALE 1:1 & 2:1	DATE OCT 1990	DRAWING NO 3107b



Jack,

dead pore pressure  
Patterson Rig

bottom ann<sup>o</sup>  
3/32



hardened  
steel.


$$\begin{array}{r}
 .588 \\
 .473 \\
 \hline
 2 \times .115 \\
 \hline
 .6575 + .118
 \end{array}$$

$$\begin{array}{r}
 1.022 \\
 .629 \\
 \hline
 .393
 \end{array}$$


reduced 86%





SECTION A-A



SECTION B-B



SECTION C-C



016 o-ring

012 o-ring


*original version*

DIMENSIONS IN MILLIMETERS - DO NOT SCALE

TOLERANCES ± UNLESS STATED

PATERSON INSTRUMENTS PTY LTD

HPT TESTING MACHINE  
AXIAL LOAD CELL  
GENERAL ASSEMBLIES





ACN 008 644 273

A3

SCALE 1:1

DATE OCT 1993


DRAWING NO 4220



	M. Naumann			
Datum	28.4.94	1: 1x 2: 2x	M 1:1	Material Alu
Z.-Nummer	3			Z.-Titel Montage Ofen - Scheibe 1 und 2
	GFZ Potsdam			


# C15 carbon steel (from GFZ)

873 K; CP = 300 MPa  
773 K; CP = 300 MPa (new)






An: Georg Dresen oder Erik Rybicki (m (617) 253-(699)  
 von: Gunter Siddipi, EAPS; MIT; Cambridge, MA 02139




Data from G. Dresen, PI #4 on steel <sup>cylinders</sup> flow




GUNTER SIDDHAI  
 54-214


$$\frac{\pi}{4} (r_o^2 - r_i^2)$$

two lead wires for each winding  
(one to earth)



Alumina Tube with Windings






$$= \sum_{run} = 236 \text{ mm}$$

$$\sum_{coll} = 342 \text{ mm}$$

$$\sum_{pp} = 32.6 \text{ mm}$$

$$= 12.82 \text{ "}$$

XPA-P13R-U-062-30-  
RP-12"



$$\phi 2 \text{ mm} = 0.079 \text{ "}$$

$$\pm 0.5 \text{ mm} = 0.020 \text{ "}$$

$$0.079 \pm 0.020 \text{ " } [ 0.059 \text{ "} - 0.099 \text{ "}]$$

$$\sum_{lun} = 236 - 5 = 231 \text{ m} = ~~9.084~~ \text{ " } 9.084 \quad 3.084$$


$$\sum_{coll} = 342 - 5 = 337 \text{ mm} = ~~13.25~~ 13.252 \quad 7.21$$

30	10 + 2.31 = 12.31\$
30	10 + 5.44 = 15.44\$



RECOMMENDED MOUNTING

pressure transducer



114-1 & 114-3

MOUNTING TORQUE  
25 Ft. Lbs.

ENLARGEMENT  
200%

1/4" HPT 141-3


MOUNTING

precise sensors use for their process connector:  
2" diameter 15-5 or 17-4 PH material  
F?/H? 900 heat treated.

- 36 BRIDGE




16172531699 P.04 TO FROM PRECISE SENSORS 5 02:01PM





- ① Balance bridge at B, using AC millimeter or oscilloscope
- ② Set front panel offset pot to 500
- ③ Adjust offset pot on distribution board to give zero <sup>AIC</sup> meter reading
- ④ Adjust zero offset in PICS to also give zero PICS reading if necessary


front of box.








Löten




M. Naumann					
Datum	18.5.95	2 x	M 2:1	Material	Messing
Z.-Nummer				Z.-Titel	The rmoel ement -Hül se
GFZ Potsdam					





MATERIAL: ASSAB 709  
OR SIMILAR




DIMENSIONS IN MILLIMETRES DO NOT SCALE	
TOLERANCES UNLESS STATED	

EXCLUSIVELY LICENCED TO PATERSON INSTRUMENTS PTY LTD			
ANU RESEARCH SCHOOL OF EARTH SCIENCES			
HIGH PRESSURE/TEMPERATURE TESTING MACHINE			
PRESSURE VESSEL ASSEMBLY			
DETAIL (13) - CAP FOR BOTTOM CLOSURE PLUG			
A3	SCALE 2:1	DATE AUG 1989	DRAWING NO 4102


REV MAR 1994

N.S. ENGINEERING SOLUTIONS PTY LTD  
 TEL: 01-07-2490100  
 25 FT. INDUSTRIAL AVENUE  
 CO. BRIDGEWAY



Title				PATERSON INSTRUMENTS	
HPT TESTING MACHINE MK11					
Size	Number	Revision			
A3	HPT/4/2				
Date:	4-OCT 1994	Sheet	2	of 5	
File:	HPT4/2	Drawn by:	A.F.		

HPT/4/2  
 A.F.  
 1994




1=SUPPLY VOLTS  
 2=BOTTOM FURNACE  
 3=CENTRE FURNACE  
 4=TOP FURNACE

↓ = ANALOG GND  
 BR1 TO BR3 ARE ULTRA FAST BREAKERS TO PROTECT THYRISTER UNITS

Title PATERSON INSTRUMENTS HPT TESTING MACHINE MKII		
Size A3	Number HPT/4/2	Revision 0
Date: 4-OCT 1994	Sheet 2 of 5	
File: HPT4/2	Drawn By: A.F.	

CONNECTIONS TO THE 24V AC SUPPLY BLOCKS TB1 AND TB2 ALSO 220V AC SUPPLY BLOCKS TB3 AND TB4 DO NOT NECESSARILY TERMINATE AT NUMBER SHOWN ON THIS DIAGRAM


Supply to Actuator Amplifiers



RELAYS IN DOTTED LINES ARE ALARM RELAYS 1 & 2 IN CONFINING PRESSURE METER. AIC Mod. (PM4-50).  
 RLY2 USED FOR DOOR INTERLOCK CONTROL.  
 RLY1 OPERATES BLEED VALVE WHEN SAFE CONFINING PRESSURE EXCEEDED.

MICROSWITCHES S1/S2 OPERATE WHEN DOOR LOCKS A & B RESPECTIVELY, ENGAGE COMPLETELY.  
 DOOR LOCKS ENGAGE WHEN DE-ENERGISED.  
 ALL RELAYS SHOWN IN DE-ENERGISED STATE. DOOR LOCKS ENGAGED UNTIL POWER APPLIED.

Title PATERSON INSTRUMENTS HPT TESTING MACHINE MKII			
Size A3	Number HPT/4/1	Revision 0	
Date: 4-OCT 1994	Sheet 1 of 5	Drawn By: A.F.	
File: HPT4/1			




▽ = ANALOG GND  
 BR1 TO BR3 ARE ULTRA FAST BREAKERS TO PROTECT THYRISTOR UNITS

Title PATERSON INSTRUMENTS HPT TESTING MACHINE MKII			
Size A3	Number HPT/4/2	Revision 0	
Date: 1-OCT 1994	Sheet 2 of 5		
File: HPT4/2	Drawn By: A.P.		



*See P1002*

Power to this offset control is supplied from the +6-12V supply located within the Internal Load Cell Pre-Amp.



I/P from J1/17 of internal load cell meter


O/P to J1/18 internal load cell meter

Title PATERSON INSTRUMENTS			
HPT Machine MKII-Load Cell 0 offset control			
Size	Number	Revision	
A3	HPT/4/3	0	
Date: 22-SEP 1994	Sheet 2 of 5	Drawn By:	
File: HPT4/3			

internal load cell Lemo conn:

look on pins

soldered shut




connector to amp



Lemo

Amp

Load cell cap.




FET 2N5485



Gunter's notebook #5 p49

For more updated  
 version see PI-002  
 left half (Channel 1)




For exact wiring  
 see handwritten sheet  
 next

Q1 and Q2 matched  
 SOT = select on test

Title				PATERSON INSTRUMENTS			
Size				HPT Testing Machine MKII/Load Cell Pre-Amp			
A3	Number	HPT/4/4		Revision	0		
Date:	27-SEP 1994	Sheet	4 of 5	Drawn By: A.F.			
File:	HPT474						

Channel 2 is not utilized.




UTC Transformer  
8-19 100-20Khz  
Max Level +20dbm

UTC Transformer  
8-19 100-20Khz  
Max Level +20dbm

Q1 and Q2 gain matched.  
Q3 and Q4 gain matched.  
SOT = select on test


Title			PATERSON INSTRUMENTS		
Size			Dual High-Z Pre Amplifier		
A3	Number	PI-002	Revision	0	
Date: 25-NOV 1994			Sheet 4 of 5		
File: PRE-AMP/1			Drawn By: A.F./N.S.		







R1 and R2 gain matched.  
 R3 and R4 gain matched.  
 SOT = select on test

Title			PATERSON INSTRUMENTS		
Dual Rish-2 Pre Amplifier					
Size	Number	Revision			
A3	PI-982	0			
Date:	25-Nov-1994	Sheet	4	of 5	
File:	PRE-AMP/1	Drawn	By: A.T./D.S.		






Title Paterson Instruments			
Data Distribution and Signal Offset.			
Size	Number	P1-01	Revision
A3			0
Date:	25-NOV 1994	Sheet	of 2
File:	P107	Drawn	By: H. Schram




Title Paterson Instruments			
Data Distribution and Signal Offset.			
Size	Number	P1-01	Revision
A3			8
Date:	25-NOV 1994	Sheet	of 2
File:	P1077	Drawn	By H. Schram

TO REZERO IC




- ① Balance bridge at B, using AC millimeter or oscilloscope
- ② Set front panel offset pot to 500
- ③ Adjust offset pot on distribution board to give zero <sup>AIC</sup> meter reading
- ④ Adjust zero offset in PICS to also give zero PICS reading if necessary

front of box.





Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the + & -15V hard wired under board to terminals as shown. 4 to 20mA terminals on these channels have also been strapped to Voltage O/P points under board. These terminals are used to repeat signals to front panel Digital Meters.



**CAUTION**


PLEASE TAKE EXTREME CARE WHEN CONNECTING THE + & -15V TO THE DCDT'S (High and Low Res Axial). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 3 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 & 6 AND -15V ON 4 & 5. THEN CONNECT THE WIRES FROM EACH DCDT RED TO 3 & 9, GREEN TO 6 & 7 AND BLACK TO 4 & 5.

FAILURE TO OBSERVE THESE PRECAUTIONS WILL RESULT IN THE INSTANT DEMISE OF THE DCDT'S, RECOVERABLE ONLY BY LARGE EXTRACTIONS FROM THE HIP POCKET.

The common connection to RLY'S (Whi wire) is taken from a convenient point on existing Servo Control Panel, as is the 24V AC (Blk wire) to SW6 and High Low Microswitches.

Title: PATERSON INSTRUMENTS			
HPT Testing Machine MKII High Resolution DCDT Wiring			
Size: A3	Number: HPT/5/6	Revision:	
Date: 26-Sep-1995	Drawn By: & F	Sheet 6 of 6	
File: D:\AD\ECR\FILES\HPT5_6.DCH			

Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the + & -15V hard wired under board to terminals as shown. 4 to 20mA terminals on these channels have also been strapped to Voltage O/P points under board. These terminals are used to repeat signals to front panel Digital Meters.



*Handwritten signature or initials in the bottom left corner.*


**CAUTION**

PLEASE TAKE EXTREME CARE WHEN CONNECTING THE + & -15V TO THE DCDT'S (High and Low Res Axial ). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 8 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 & 6 AND -15V ON 4 & 5. THEN CONNECT THE WIRES FROM EACH DCDT RED TO 8 & 9, GREEN TO 6 & 7 AND BLACK TO 4 & 5

FAILURE TO OBSERVE THESE PRECAUTIONS WILL RESULT IN THE INSTANT DEMISE OF THE DCDT'S, RECOVERABLE ONLY BY LARGE EXTRACTIONS FROM THE HIP POCKET



Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the +0.15V hard wired under board to terminals as shown. 4 to 20mA terminals on these channels have also been strapped to Voltage O/P points under board. These terminals are used to repeat signals to front panel Digital Meters.



### CAUTION


PLEASE TAKE EXTREME CARE WHEN CONNECTING THE +0.15V TO THE DCDT'S (High and Low Res Axial). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 8 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 & 6 AND 15V ON 4 & 5. THEN CONNECT THE WIRES FROM EACH DCDT RED TO 8, GREEN TO 6 & 7 AND BLACK TO 4 & 5.

FAILURE TO OBSERVE THESE PRECAUTIONS WILL RESULT IN THE INSTANT DESTRUCTION OF THE DCDT'S, RECOVERABLE ONLY BY LARGE EXTRACTIONS FROM THE HIP SOCKET.

The common return to RLY9 (Wh wire) is taken from a convenient point on existing Servo Control Panel, as is the 24V AC (Blk wire) to SW6 and High Low Microswitches.

FATEKON INSTRUMENTS			
HPT Testing Machine MEH High Resolution C/U/T Wagon			
Tab	Model	Revision	
Site	<b>HPT/5/6</b>		
Date	Drawn By	Checked By	
File	Drawn By		Checked By

Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the +&-15V hard wired under board to terminals as shown. 4 to 20mA terminals on these chan's have also been strapped to Voltage O/P points under board. These terminals are used to repeat signals to front panel Digital Meters.



**CAUTION**


PLEASE TAKE EXTREME CARE WHEN CONNECTING THE +&- 15V TO THE DCDT'S (High and Low Res Anal). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 8 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 & 6 AND -15V ON 4 & 5 THEN CONNECT THE WIRES FROM EACH DCDT RED TO 8 & 9, GREEN TO 6 & 7 AND BLACK TO 4 & 5

FAILURE TO OBSERVE THESE PRECAUTIONS WILL RESULT IN THE INSTANT DEMISE OF THE DCDT'S, RECOVERABLE ONLY BY LARGE EXTRACTIONS FROM THE HIP POCKET

The common connection to RLYS (Whit wire) is taken from a convenient point on existing Servo Control Panel, as is the 24V AC (Blk wire) to SW6 and High/Low Microswitches

Title			
PATERSON INSTRUMENTS			
HPT Testing Machine MKII High Resolution DCDT Wiring			
Size	Number	Revision	
A3	<b>HPT/5/6</b>		
Date	16-Oct-1995	Sheet 6 of	6
File	D:\ADV\SCH\FILES\HPT5_6.SCH	Drawn By	A F

Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the +&-15V hard wired under board to terminals as shown. 4 to 20mA terminals on these channels have also been strapped to Voltage O/P points under board. These terminals are used to repeat signals to front panel Digital Meters.



**CAUTION**

PLEASE TAKE EXTREME CARE WHEN CONNECTING THE +&- 15V TO THE DCDT'S (High and Low Res Axial ). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 8 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 AND -15V ON 4 & 5. THEN CONNECT THE WIRES FROM EACH DCDT RED TO 8 & 9, GREEN TO 6 & 7 AND BLACK TO 4 & 5.


FAILURE TO OBSERVE THESE PRECAUTIONS WILL RESULT IN THE INSTANT DEMISE OF THE DCDT'S, RECOVERABLE ONLY BY LARGE EXTRACTIONS FROM THE HIP POCKET.

The common connection to RLY8 (Wht wire) is taken from a convenient point on existing Servo Control Panel, as is the 24V AC (Blk wire) to SW6 and High Low Microswitches.

Title			PATERSON INSTRUMENTS		
			HPT Testing Machine MKII High Resolution DCDT Wiring		
Size	Number	Revision			
A4		<b>HPT/5/6</b>			
Date	23-03-1995	Sheet 6 of	6		
File	D:\AD\VSCHFILES\HPT5_6.SCH	Drawn By	AF		



Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the + & -15V hard wired under board to terminals as shown. 4 to 20mA terminals on these channels have also been strapped to Voltage OP points under board. These terminals are used to repeat signals to front panel Digital Meters.



### CAUTION


PLEASE TAKE EXTREME CARE WHEN CONNECTING THE + & -15V TO THE DCDT'S (High and Low Res Axial). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 3 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 & 6 AND -15V ON 4 & 8. THEN CONNECT THE WIRES FROM EACH DCDT RED TO 3 & 9, GREEN TO 6 & 7 AND BLACK TO 4 & 8.

FAILURE TO OBSERVE THESE PRECAUTIONS WILL RESULT IN THE INSTANT DESTRUCTION OF THE DCDT'S, RECOVERABLE ONLY BY LARGE EXTRACTION FROM THE HPT SOCKET.

The common connection to RLY8 (White wire) is taken from a common point on existing Servo Control Panel, as is the 24V AC (Blk wire) to SW6 and High/Low Microswitches.



Task: PATTERSON INSTRUMENTS			
HPT Testing Machine MEJ High Resolution DCVT Wiring			
Rev	Number	Sheet No.	Revision
A.1	HPT/5/6	5	A.1
Date:	12/10/92	Drawn by:	W. J. P.
File:	PLANS/5/6/5/6	Checked by:	A. P.

Chan 0 Terminal Block is Located on the Analog Devices Signal Conditioning Board and along with Chan's 1 and 2 has the +&- 15V hard wired under board to terminals as shown. 4 to 20mA terminals on these channels have also been strapped to Voltage O/P points under board. These terminals are used to repeat signals to front panel Digital Meters.



### CAUTION

PLEASE TAKE EXTREME CARE WHEN CONNECTING THE +&- 15V TO THE DCDT'S (High and Low Res Axial). MAKE ABSOLUTELY SURE THE +15V IS ON CONNECTIONS 8 & 9 OF THE NEW TERMINAL BLOCK, COM ON 5 & 6 AND -15V ON 4 & 5. THEN CONNECT THE WIRES FROM EACH DCDT RED TO 8 & 9, GREEN TO 6 & 7 AND BLACK TO 4 & 5.



High resolution

DCDT



received from MSP 21SEP95

## NOTES ON THE INSTALLATION AND USE OF THE HIGH-RESOLUTION DCDT FOR AXIAL DISPLACEMENT MEASUREMENT AND CONTROL

### INSTALLATION

Mount the switch panel on the platform frame immediately above the actuator switch panel and PICS. Mount the relay and connector board in an appropriate place for making the connections to the transducers. In the case of the Potsdam machine, this place will be on the inside wall of the instrument compartment, on the platform side, at the same level as the meters. In the case of the MIT machine, it will be adjacent to the Analog Devices transducer conditioning board, possibly most conveniently on the inside of the back panel underneath the platform.

Mount the unit on the side of the yoke using two M6 screws and remove the retaining pin in the core extension so as to allow the core to register on the bottom side of the pressure vessel. Then attach the flexible drives to the two shafts projecting on the LH side of the unit. The lower drive serves for remote positioning of the unit and the upper one for locking it in position. The other ends of the flexible drives are to be mounted with suitable clamps on the side of the housing just below the level of the desk so that they can be manipulated while observing the positioning lights on the switch panel. It will be necessary to cut a slot in the top of the panel enclosing the lower side of the machine in order to accommodate the flexible drives. The flexible cables will enter the high pressure enclosure through the vent between the intensifier and the wall, and curve around the intensifier.

The leads that at present go from the actuator DCDT to the POSITION meter (in the Potsdam case) or to the Analog Devices board (in the MIT case) have to be redirected to the connector board and new leads run from the connector board to the meter or AD board, respectively, according to the wiring diagram supplied. The other leads from the connector board go to the switch panel. A 24 V ac supply line are shown in the diagram being taken from the existing actuator switch panel to the new switch panel but this can be taken from anywhere convenient. It is very important in connecting up to ensure that the polarity of the supply to the DCDT's be preserved as at present since reversal of the supply to DCDT tends to destroy it (there seems to be no inbuilt protection in the Schaevitz units).

Note that the Schaevitz 050 DC-E DCDT (range  $\pm 1.25$  mm) is mounted with its leads emerging from the top end in order to give the same output polarity as the output from the actuator DCDT. The mounting unit has been dimensioned so that the next larger sized Schaevitz, the 125 DC-E DCDT with  $\pm 3.0$  mm range, can alternatively be used if a 6 mm range is desired instead of the 2.5 mm range that the 050 DC-E gives, with corresponding reduction in resolution.

## OPERATION


The HR DCDT unit is designed to enable the operation of the testing machine in axial displacement (AD) mode with a step size of axial displacement advance of 1/20 of that obtained using the actuator DCDT output as feedback, that is, 0.6  $\mu\text{m}$  instead of 12  $\mu\text{m}$ . Finer resolution data logging is then also provided. Further, since the measurement is effectively made where the loading piston emerges from the pressure vessel, the apparatus distortion corrections will be reduced in magnitude. The piston travel available with control from the HR DCDT is 2.5 mm, corresponding to about 12% strain. The experiment is therefore normally limited to this amount of displacement. If more is required, it will be necessary to interrupt the experiment, re-position the HR DCDT unit and repeat the operation, or install a DCDT of 6 mm range. However, it might be expected that with larger-strain experiments the actuator step size will be less critical and that therefore the normal actuator DCDT will be used for feedback and data logging.

In using the HR DCDT facility the following procedures should be followed and precautions observed:

1. Position the actuator where the experiment is to start. This is preferably done with the confining pressure and temperature conditions for the experiment already established and the piston position at or near the touchpoint. Note the absolute actuator position if required.
2. Position the HR DCDT unit so that its core is near the end of its range. This can be done using the flexible drives, first unclamping the unit with the upper drive and then moving it to the required position with the lower drive and finally clamping it again with the upper. The positioning lights on the switch panel, actuated by microswitches on the unit, are used for guidance. The microswitches must be set so that the respective lights are turned on when the core of the HR DCDT is at its upper and lower measuring limits (this setting will need to be done in the first set-up but, once done, will remain valid for other positions of the DCDT). In a compression test, the unit is moved down until the LOW light comes on and then moved back until the light is just extinguished again, ensuring that the whole of the linear range of 2.5 mm is available for the experiment.
3. With the actuator motor switched off (very important):
  - (a). Turn the change-over switch on the switch panel to the HR DCDT position.
  - (b). On the PICS AD status screen, select the CALIBRATION option and set the DCDT calibration to 2.5 mm.
  - (c). Set the axial displacement limits as required; probably, 0 and 2.5 will normally be appropriate.
4. Now the actuator can be switched on and the experiment carried out in the normal way.
5. After switching back to the normal DCDT, the calibration setting in the PICS must be reset to 50 mm and new limits set.

Note that, with the HR DCDT switched in, the POSITION digital meter on the main panel will be reading in units of 1/20 mm, that is, the readings have to be divided by 20 to obtain the relative position in millimetres; this position will be relative to the new zero established by the positioning of the HR DCDT unit.






*suspect the drawing is not quite what we have; filter/attenuator*

Title PATERSON INSTRUMENTS			
HPT Testing Machine MKII/Servo Amps			
Size A3	Number HPT/4/5	Revision 0	
Date: 4-OCT 1994	Sheet 5 of 5	Drawn By:	
File: HPT4/5			

54- vrb

CONNECTIONS TO THE 24V AC SUPPLY BLOCKS TB1 AND TB2 ALSO 220V AC SUPPLY BLOCKS TB3 AND TB4 DO NOT NECESSARILY TERMINATE AT NUMBER SHOWN ON THIS DIAGRAM




RELAYS IN DOTTED LINES ARE ALARM RELAYS 1 & 2 IN CONFINING PRESSURE METER, AIC Mod. (PH4-5a).  
 RLY2 USED FOR DOOR INTERLOCK CONTROL.  
 RLY1 OPERATES BLEED VALVE WHEN SAFE CONFINING PRESSURE EXCEEDED.

MICROSWITCHES S1/S2 OPERATE WHEN DOOR LOCKS A & B RESPECTIVELY. ENGAGE COMPLETELY.  
 DOOR LOCKS ENGAGE WHEN DE-ENERGISED.  
 ALL RELAYS SHOWN IN DE-ENERGISED STATE. DOOR LOCKS ENGAGED UNTIL POWER APPLIED.

Title			PATERSON INSTRUMENTS		
HPT TESTING MACHINE HKII					
Size	Number	Revision			
A3	HPT/4/1	0			
Date:	4-0CY 1994	Sheet	1 of 5		
File:	HPT/4/1	Drawn	Rvi A.F.		

Figure 2-1. -3a. Control system wiring diagram



Title			
PICS WIRING DIAGRAM			
Size	Number	PICS-UIR	Revision
A3			0
Date:	20-MAR 1995	Sheet	1 of 2
File:	PICS-UIR/1	Drawn	Bwi Schram

MIT VOL MOTOR

Test certificate

Printed Motors



Printed Motors Limited  
 Bordon Trading Estate, Oakhanger Road, Bordon, Hampshire GU35 9HY  
 Telephone: 0420 473033. Telex: 858768. Fax: 0420 477640.

DELETE INAPPLICABLE TYPES:- SERVO MOTOR/MOTOR TACHOGENERATOR/TACHOMETER/GENERAL PURPOSE MOTOR				
WORKS ORDER NO.....		20758/A		
CATALOGUE NO.....		GMP11009T-2244		
SERIAL NO.....		87980		
DATE.....		12-7-94		
Motor	KE	VOLTS/1000 RPM	C.W. 4.94 A.C.W. 4.97	
	KD	NCM OZ-INS/1000 RPM	1.08	
	TF	NCM OZ-INS	2.08	
	RM	OHMS	183	
	Direction of Rotation / End Float		Ins	10001 10001 Sig
	Shaft Runout		B.E. INS. T.I.R. C.E.	10004 10003
	Mounting Concentricity		INS. T.I.R.	10008
	Perpendicularity Mounting Face		INS. T.I.R.	10039
	Insp. Stamp	Insulation Resistance $\geq$ 50 Megohms		Sig
	Both Copies	Insulation Resistance Tach/Motor Armature $\geq$ 50 Megohms		Sig
Tacho	KE Volts/1000 RPM	CW ACW		
	Residual Ripple Peak/Peak Volts at 1000 RPM		CW ACW	
	Polarity		Sig	
Insp. Stamp	Insulation Resistance $\geq$ 50 Megohms		Sig	
Both Copies	Insulation Resistance $\geq$ 50 Megohms		Sig	

DEFINITIONS

- KE — Back EMF at 1000 RPM into meter of not less than 20 K OHMS per volt impedance.
- KD — Damping Constant at 1000 RPM.
- TF — Friction torque (at 50 RPM).
- RM — Terminal resistance measured by passing 5 AMPS DC from constant current source through motor and measuring volt drop across terminals at 50 RPM.

RESIDUAL RIPPLE. Measured through filter as specified on outline drawing at 1000 RPM on oscilloscope.

DIRECTION OF ROTATION. As specified on outline drawing.

POLARITY. As specified on outline drawing.


All tests carried out with motor/tacho under test at room ambient conditions.

Top copy — Inspection File.  
 2nd copy — Customers Inspection  
 3rd copy — Accounts/Sales



MIT ACTUATOR motor

Printed Motors



Test certificate

Printed Motors Limited  
 Bordon Trading Estate, Oakhanger Road, Bordon, Hampshire GU35 9HY  
 Telephone: 0420 473033. Telex: 858768. Fax: 0420 477640.

DELETE INAPPLICABLE TYPES:- SERVO MOTOR/MOTOR TACHOGENERATOR/TACHOMETER/GENERAL PURPOSE MOTOR				
WORKS ORDER NO.....		20002		
CATALOGUE NO.....		G9T-2		
SERIAL NO.....		86413	DATE 20-7-93	
Motor	KE	VOLTS/1000 RPM	C.W. A.C.W.	
	KD	OZ.INS/1000 RPM		
	TF	OZ.INS		
	RM	OHMS		
	Direction of Rotation / End Float		Ins	Sig
	Shaft Runout		B.E. C.E.	INS. T.I.R.
	Mounting Concentricity			INS. T.I.R.
	Perpendicularity Mounting Face			INS. T.I.R.
Insp. Stamp	Insulation Resistance		≥ 50 Megohms Sig	
Both Copies	Insulation Resistance Tach/Motor Armature		≥ 50 Megohms Sig	
Tacho	KE Volts/1000 RPM	CW ACW	3.11 3.09	
	Residual Ripple Peak/Peak Volts at 1000 RPM		CW ACW	1.084 1.088
	Polarity			Sig
Insp. Stamp	Insulation Resistance		≥ 50 Megohms Sig	
Both Copies	Insulation Resistance		≥ 50 Megohms Sig	

DEFINITIONS

- KE — Back EMF at 1000 RPM into meter of not less than 20 K OHMS per volt impedance.
- KD — Damping Constant at 1000 RPM.
- TF — Friction torque (at 50 RPM).
- RM — Terminal resistance measured by passing 5 AMPS DC from constant current source through motor and measuring volt drop across terminals at 50 RPM.

RESIDUAL RIPPLE. Measured through filter as specified on outline drawing at 1000 RPM on oscilloscope.

DIRECTION OF ROTATION. As specified on outline drawing.

POLARITY. As specified on outline drawing.

All tests carried out with motor/tacho under test at room ambient conditions.

- Top copy — Inspection File.
- 2nd copy — Customers Inspection
- 3rd copy — Accounts/Sales





1 psi = 0.006894757 MPa

MITT

CALIBRATION  
CALIBRATION CERTIFICATION  
PRECISE  
PRECISE SENSORS, INC.  
235 WEST CHESTNUT AVENUE  
MONROVIA, CALIFORNIA 91016  
(818) 358-4578

DOWNSTREAM

MODEL NO. 114-3-60,000-01-G-34-13-BE6

SENSITIVITY 2.984 mV/V  
3.607 mV/V for 500 MPa

SERIAL NO. 42094

INPUT RESISTANCE 351 OHMS

EXCITATION 10 VDC 413.7 MPa

OUTPUT RESISTANCE 351 OHMS

PRESSURE RANGE 0-60000 PSIG 419.7 MPa

MOUNTING TORQUE 25 FT. LBS.

COOLANT INLET PRESSURE N/A

SHUNT CAL 80.75% OF F.S.O.

CERTIFICATION NO. 10-11801

CUSTOMER COLLINS & ASSOCIATES, INC.

CUSTOMER P.O. NO. 21387

INPUT PRESSURE  
% OF FULL SCALE

INCREASING

OUTPUT IN %  
DECREASING

0%	0.00	0.09
10%	10.23	10.64
20%	19.82	20.93
40%	39.57	40.12
60%	59.71	60.07
80%	79.82	80.02
100%	100.00	—

WIRING IDENTIFICATION

- A +SIGNAL
- B -SIGNAL
- C -EXCITATION
- D +EXCITATION
- E SHUNT
- F SHUNT

CALIBRATED BY RAUL NAVARRETTE

INSPECTED BY

PSI  
4

DATE 7-29-94

NOTE: Calibration performed at 72°F ±2°F unless otherwise noted. Calibration data as supplied are based on test performed on the values obtained with N.I.S.T. traceable laboratory standards.

FORM 233

## INDIVIDUAL TECHNICAL SHEET

-----

SENSOR TYPE : PR 851 C  
SERIAL NUMBER : 34  
PRESSURE RANGE : 7000 bar  
GAUGE : Métallic

### CALIBRATION

-----

ALIMENTATION : 10 V                      TEMPERATURE : 22 °C

#### PRESSURE

#### MESURE

1	0 bar	0 mV
2	3500 bar	5.426 mV
3	7000 bar	10.941 mV
4		
5	CRAN	5.287 mV
6	CRAN	3410 bar
7		
8		
9		


LIN-HYST : 0,40 %      ISOLEMENT SOUS 50 V : 1000 M ohms

MANUFACTURING CONTROL :

Date : 16 juin 1994

FINAL QUALITY CONTROL :

Date : 16 juin 1994



PH. LAGRUE



1 psi = 0.0068948 MPa

MIT

CALIBRATION CERTIFICATION

PRECISE SENSORS, INC.  
235 WEST CHESTNUT AVENUE  
MONROVIA, CALIFORNIA 91016  
(818) 358-4578

MODEL NO. 114-3-60,000-01-G-34-13-BE6

UPSTREAM

SENSITIVITY 2.838 mV/V  
3.430 for 500 MPa  
INPUT RESISTANCE 351 OHMS

SERIAL NO. 42095

EXCITATION 10 VDC 413.7 MPa

OUTPUT RESISTANCE 351 OHMS

PRESSURE RANGE 0-60000 PSIG 413.7 MPa

MOUNTING TORQUE 25 FT. LBS.

COOLANT INLET PRESSURE N/A

SHUNT CAL 80.33% OF F.S.O.

CERTIFICATION NO. 10-11801

CUSTOMER COLLINS & ASSOCIATES, INC.

CUSTOMER P.O. NO. 21387

INPUT PRESSURE % OF FULL SCALE	OUTPUT IN %	
	INCREASING	DECREASING
0%	0.00	0.04
10%	10.06	10.51
20%	19.66	20.52
40%	39.06	40.89
60%	59.18	60.83
80%	79.55	80.24
100%	100.00	—

WIRING IDENTIFICATION

- A +SIGNAL
- B -SIGNAL
- C -EXCITATION
- D +EXCITATION
- E SHUNT
- F SHUNT

CALIBRATED BY RAUL NAVARRETTE

INSPECTED BY

PSI  
4

DATE 7-29-94

NOTE: Calibration performed at 72°F ±2°F unless otherwise noted. Calibration data as supplied are based on test performed on the values obtained with N.I.S.T. traceable laboratory standards.

FORM 233



# Transducer Techniques

PRECISION MEASUREMENT SYSTEMS

MIT  
(recal)

<<< CERTIFICATE OF CALIBRATION >>>

SERIAL NUMBER: 70744  
 SENSOR MODEL: SWP-20K  
 JOB NUMBER: 7687  
 TECHNICIAN: VL

DATE OF CALIBRATION: 05/26/94  
 DATE OF RECALIBRATION: 05/26/95

COMPRESSION LOAD LBS.	MV/V INC.	MV/V DEC.
0	0	0
10000 <i>44.48 kN</i>	1.2979	1.2976
20000 <i>88.96 kN</i>	2.5989	
<i>100 kN</i>	<i>2.9214</i>	
NON-LINEARITY	.06	PCT FS
NON-REPEATABILITY	-.02	PCT FS
HYSTERESIS	-.02	PCT FS

<< SHUNT CALIBRATION >>

PCT LOAD	LOAD LBS	SIGNAL MV/V	SHUNT K OHMS	SHUNT PINS
38.5	7703.5	1.0011	174.825	(-E.-S)
77.0	15407.0	2.0021	87.325	(-E.-S)

<< DIGITAL PANEL METER MODEL DPM-2 SCALE FACTOR >>  
 DPM-2 SCALE FACTOR -2.3086

- \* CALIBRATION COMPUTED FROM THREE (3) RUNS INCREASING AND DECREASING.
- \* TRACEABLE TO NIST TEST # 56027
- \* CALIBRATION PERFORMED AT 10 VDC
- \* MAXIMUM BRIDGE EXCITATION 12 VDC

WIRING COLOR CODE

PINS	CABLE	
A	RED	+EXCITATION
D	BLK	-EXCITATION
C	GRN	+SIGNAL
B	WHT	-SIGNAL
E	BRN	-SIGNAL R-CAL
F	BLU	+SIGNAL R-CAL
	SHD	GROUND